

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 142


Dated: 12.03.2026

It is certified that an inspection team headed by Ex. MUKESH KUMAR (A.E.) (Name of Officers with designation) from Uttarakhand Jal Sansthan, Rudrapur

inspected the **BRIGHT START INTERNATIONAL ACADEMY, JASPUR, U S NAGAR, UTTARAKHAND** on 12.03.2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 142/UIS/DLWOTML dated 12.03.2026 of DLWOTML UIS, RUDRAPUR (U.S. Nagar) (PHED Lab)

certified that the **BRIGHT START INTERNATIONAL ACADEMY, JASPUR** has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U. T . Govt.

This certificate is valid till 11.03.2027

Signature with Seal: 

Name: Ex. MUKESH KUMAR

Designation: Assistant Executive Engineer

Name & Address of the Office/Department:

Uttarakhand Jal Sansthan
Rudrapur, U.S. Nagar

To

BRIGHT START INTERNATIONAL ACADEMY
Near Govindpur Gurudwara, Jagatpur Patti
NH-734, Kashipur Road, Jaspur
Udham Singh Nagar, Uttarakhand - 244712

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Rudrapur U.S. Nagar

E-mail: eeudmujs@gmail.com

Test Report ID: 142/UJS/DLWQTML/2025-26

WATER QUALITY TEST REPORT


Name and Address of Organization/ Customer	Bright Start International Academy, Jaspur(U.S.Nagar)		
Type of Source :	Drinking Water	Sample Description: One water Sample submitted from UV RO Machine.	
Reference Sample Identification:	DLWQTML/UJS/BSI-01	Date of Start of Analysis: 11.03.2026	
		Date of End of Analysis : 12.03.2026	
Date of Sample Received: 11.03.2026	Sample Collected by:	Customer	

SN	Parameters	Test Method	Result	Requirement Acceptable Limit As per (IS10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
1.	pH at 25 ⁰ C	IS 3025 (Part 11) 2022,	7.57	6.5 to 8.5	No Relaxation
2.	Total Dissolved Solids (TDS), at 180 ⁰ C	IS 3025 (Part 16), 2023	130	500 Max	2000 Max
3.	Turbidity, NTU	IS 3025 (Part 10), 2023	0.45	1 Max	5 Max
4.	Total Alkalinity (as CaCO ₃), mg/l	IS 3025 (Part 23), 2023	69	200 Max	600 Max
5.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21), 2009	60	200 Max	600 Max
6.	Calcium as Ca, mg/l	IS 3025 (Part 40), 2019,	16.0	75 Max	200 Max
7.	Chloride, mg/L	IS 3025 (Part 32), 2019	6.99	250 Max	1000 Max
8.	Magnesium as Mg/l	APHA 24 th Ed -3500-Mg Method B:2023 (Calculation Method)	4.86	30 Max	100 Max
9.	Colour, Hazen	IS 3025 (Part 4): 2021	Less than 5	5 Max	15 Max
10.	Odour	IS 3025 (Part 5) : 2018	Agreeable	Agreeable	Agreeable
11.	E.Coli, MPN/ 100 ml	APHA 23 rd Ed.-9223-B	Absent	Absent	Absent
12.	Total Coliform, MPN/100ml	APHA 23 rd Ed.-9223-B	Absent	Absent	Absent

Remark: Above received water sample conforms to IS: 10500-2012 for drinking purpose with respect to above tests.


Chemist

-End of Report -


Lab Incharge/Quality Manager
Technical Manager
District Water Quality Testing
Monitoring Laboratory
Uttarakhand Jal Sansthan, U.S. Nagar