



No. 4116 /MIHAN/FIRE/2025

Date: 22/08/2025

Renewal of Part Fire Safety Approval

To,
Shri.Chiranjilal Bajoria Education Society
"Dehli Public School". Plot No.07,
Sector-21, MIHAN, Nagpur-441108

Subject : Renewal of Part Fire Safety Approval for Shri.Chiranjilal Bajoria Education Society, "Dehli Public School", Plot No.07, Sector-21, MIHAN, Nagpur-441108

Ref. : 1) Application No.CLBES/NGP/25-26/19, dtd. July 28th, 2025, MADC Inward No.4180, dtd.28.07.2025.
2) Part Fire Safety Approval No.3518/MIHAN/FIRE/2024, dtd.05.08.2024.

As per application from Shri.Chiranjilal Bajoria Education Society, "Dehli Public School", Plot No.07, Sector-21, MIHAN, Nagpur-441108, for Renewal of Part Fire Safety Approval. With application form "B" from M/s. Pree Engineering having license No.MFS/LA/RF-88, MFS/LA/RD-83, MFS/LA/P-26 & Annexure for execution/maintenance, are attached herewith.

The site has been inspected by Fire & Emergency Services, MADC, MIHAN Nagpur, on dtd.19/08/2025. The Fire fighting and safety arrangements which was stated in Provisional Fire NOC tested and found that same installations are in working condition.

Terms & conditions:-

- 1) Renewal of Part Fire Safety Approval is granted for one year only.
- 2) Renewal of Part Fire Safety Approval to be renew every year from MADC, Nagpur.
- 3) Open space should be kept free of obstructions around the building.
- 4) All staff and guards should be trained to operate and handling fire fighting equipments.
- 5) Emergency Plan should be prepared.
- 6) For Fire Fighting rescue & evacuation mock drill carried out once in a 3 months.
- 7) Applicant should properly maintain all fire fighting, fire protection, fire prevention & safety equipment installation regularly.
- 8) MADC reserve the right to amend/change condition or impose new conditions considering the safety requirements of life, property, building, & surroundings.
- 9) The condition of the certificate shall be binding not only the applicant but also its successors and every persons deriving title through or under him.

Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B-Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Phone: +91-0712-2815621 ● Fax: +91-0712-2815600 ● Email: jmd@madcindia.org

Website: <https://madc.maharashtra.gov.in>

In Witness Whereof

DyCFO/Aug-25/RPFFC -DPS 210825.doc

Principal

DELHI PUBLIC SCHOOL
Opp IIM & AIIMS Hospital,
Wardha Road, Nagpur-441108



- 10) Every year there will be inspection by Fire Officer of MADC.
- 11) During the occupancy of the building if anything happens due to non compliance the fire protection, fire prevention & safety equipment installation as stated in the certificate. The entire responsibility lies with occupier/owner and its other professional responsible building development. In no case, MADC shall be held responsible for any lapse of whatever reason by occupier/owner & its other professionals.
- 12) Storage of water for firefighting purpose shall always be available with alternative source of supply.
- 13) Qualified Fire Officer with experience of not less than 2-3 year shall be appoint who will be available on the premises.
- 14) Remaining part of building and floor should not be occupied without Fire Fitness Certificate.
- 15) Every six month the applicant have to inform in written regarding all firefighting, fire protection, fire prevention, safety arraignments and equipments are in working conditions to fire officer.
- 16) Form "B" from licence agency should be submitted at the time of renewal or January & July.
- 17) At the time of inspection if the fire fighting & safety installation not found in working condition. as stated in provisional fire NOC. The renewal of part safety approval will be cancelled without preintimation.
- 18) Submit yearly annual electric audit report at the time of renewal of fire safety approval.

Valid up to: 08/07/2026


Dy. Chief Fire Officer
Fire & Emergency Services
MADC, Ltd. Nagpur

Copy to : Office In charge (PO), MADC Nagpur for information please.




Principal
DELHI PUBLIC SCHOOL
Opp IIM & AIIMS Mihan
Wardha Road, Nagpur-441108

Maharashtra Airport Development Company Ltd.

(A Government of Maharashtra Undertaking)

CIN:U45203MH2002SGC136979

Central Facility Building, B - Wing (North), 1st Floor, MIHAN SEZ, Khapri (Rly.), Nagpur - 441 108

Tel: +91 -0712 -2815621 ● Fax: +91-0712 2815600 ● Email: jmd@macindia.org

● Website: <https://madc.maharashtra.gov.in>