

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”



**DELHI JAL BOARD ;(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085**



(ISO Certified 9001:2015)

THE TEST REPORT IS VALID FOR THIS PARTICULAR SAMPLE ONLY

Water samples collected from: - S1:- DJB Stored Water; S2:- Drinking Point In the premises of New Era Public School, H-17 main Mayapuri Road, Mayapuri New Delhi - 110064 vide challan no. 54 dated 29.05. 2025.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	-----11.06.2025-----	
2.	Date of Analysis	--	---	---	-----13.06.2025-----	
3.	Colour	C.U.	5	15	3 C.U	3 C.U
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	3.15	2.70
6.	p ^H value	--	6.5 to 8.5	N.R.	7.5	7.4
7.	Electrical Conductivity	µmhos/cm	----	----	308.0	257.0
8.	Total Dissolved Solid	(mg/l)	500	2000	200.2	167.05
* CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	82.0	74.0
11.	Total Hardness	(mg/l)	200	600	124.0	116.0
12.	Calcium Hardness	(mg/l)	----	----	88.0	78.0
13.	Magnesium Hardness	(mg/l)	----	----	36.0	38.0
14.	Calcium as Ca	(mg/l)	75	200	35.2	31.2
15.	Magnesium as mg	(mg/l)	30	100	8.64	9.12
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	2.39	1.89
19.	Sulphate (SO ₄)	(mg/l)	200	400	37.63	34.34
20.	Chloride (Cl)	(mg/l)	250	1000	18.0	14.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.03	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.49	0.36
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.50	Nil
* BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37 ^o c	MPN/100 mL	0	0	0	0


Remarks: Remarks: On the basis of tested parameters, water sample 'S1' & 'S2' confirm to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist


A.C.W.A.

C. W. A. (W&S)-II





MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No.DHO/WZ/2025/D 1840

Dated: 14/10/25

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter no DHOWZ/2024/D-1650, dated 14.10.2024. The school premises were re-inspected by officials of the Public Health Department in the presence of school management, and found to be in sanitary and hygienic condition from a health point of view. The details are as follow:

Name of the school: M/s New Era Public School

Address of School: H-17, Maya Puri, New Delhi-110064

Shifts: ONE Timing: MORNING

No. of Students: Boys:- 1442 Girls:- 1223 Total:- 2665

No. of Staff (Teachers): Female:- 108 Male:- 30 Total:- 138

That the accommodation provided for the class rooms as calculated.

- (A) On floor space is sufficient Yes
(B) On Cubic space is sufficient Yes
- That the classrooms are well ventilated Yes
- That the classrooms are kept neat and clean Yes
- That the classrooms are well lighted Yes
- That the drinking water is wholesome Wholesome
- That the latrines arrangement is adequate and there are sufficient latrines.
- That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of issue.

Dy. Health Officer
West Zone
MED/19
Dy. Health Officer
West Zone