



DELHI JAL BOARD ; (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT HAIDERPUR,
DELHI-110085



(ISO Certified 9001:2015)

**THE TEST REPORT IS
FOR THIS PARTICULAR
WATER SAMPLE ONLY**

Water samples collected from: - **S1:-** Outlet of Storage Tank (DJB Supply); **S2:-** Students Drinking Point (R.O. Treated) at Ground Floor, from the premises of **New Era Public School**, H-17 Main Mayapuri Road, Mayapuri, New Delhi-64, vide challan no. 114, dated 25.06.2026.

S. No.	PARAMETERS	UNITS	B.I.S.10500:2012		S1	S2
			Desirable	Permissible		
1.	Date of Collection	--	---	---	-----30.06.2026-----	
2.	Date of Analysis	--	---	---	-----01.07.2026-----	
3.	Colour	C.U.	5	15	<1.0	<1.0
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	2.08	0.67
6.	p ^H value	--	6.5 to 8.5	N.R.	7.51	7.52
7.	Electrical Conductivity	µmhos/cm	----	----	282.0	91.0
8.	Total Dissolved Solid	(mg/l)	500	2000	183.0	59.0
* CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	----	----	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	66.0	24.0
11.	Total Hardness	(mg/l)	200	600	111.0	33.0
12.	Calcium Hardness	(mg/l)	----	----	80.0	23.0
13.	Magnesium Hardness	(mg/l)	----	----	31.0	10.0
14.	Calcium as Ca	(mg/l)	75	200	32.0	9.0
15.	Magnesium as mg	(mg/l)	30	100	7.4	2.4
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	0.05	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	0.010	ND
18.	Nitrate NO ₃	(mg/l)	45	N.R.	2.22	0.85
19.	Sulphate (SO ₄)	(mg/l)	200	400	40.61	14.8
20.	Chloride (Cl)	(mg/l)	250	1000	18.0	6.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.08	ND
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.57	0.10
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	ND	ND
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.50	Nil
* BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37 ^o c	MPN/100 mL	0		0	0

Remarks: On the basis of tested parameters, water samples 'S1' & 'S2' confirm to drinking water specification IS.10500:2012 and may be used for drinking purpose.

Asstt. Chemist

Chemist/Bacteriologist

f A.C.W.A.(HP-I)

MANAGER
NEW ERA PUBLIC SCHOOL





MUNICIPAL CORPORATION OF DELHI
PUBLIC HEALTH DEPARTMENT, WEST ZONE
DR. SAHIB SINGH VERMA NIGAM BHAWAN
SHIVAJI ENCLAVE, RAJA GARDEN, NEW DELHI - 110027



No. DHO/WZ/2026/D- 1848

Dated: -09/10/26

HEALTH CERTIFICATE

In further continuation of this, a School Health Certificate was issued vide letter No. DHO/WZ/2025/D-1840 dated 14-10-2025. The school premises were re-inspected by officials of the Public Health Department in the presence of school management, and found to be sanitary and hygienic condition from a health point of view. The details area as follow:

Name of the school: **M/s New Era Public School**

Address of School: **H-17, Maya Puri, New Delhi-110064**

Shifts: ONE

Timing: MORNING

No. of Students: Boy's:-1395 Girls:-1212 Total:- 2607

No. of Staff (Teachers): Female:-100 Male:-33 Total:- 133

That the accommodation provided for the class rooms as calculated.

1. (A) On floor space is sufficient Yes
- (B) On Cubic space is sufficient Yes
2. That the classrooms are well ventilated Yes
3. That the classrooms are kept neat and clean Yes
4. That the classrooms are well lighted Yes
5. That the drinking water is wholesome Wholesome
6. That the latrines arrangement is adequate and there are sufficient latrines.
7. That urinals arrangement is adequate and there are sufficient urinals

This certificate is issued for sanitary and hygienic conditions from the health point of view of the school, premises. This certificate has no bearing structure stability/ unauthorized construction and fire safety. This certificate is valid for one year from the date of Issue.



**DY. HEALTH OFFICER
WEST ZONE**

Dated: 09/10/26
WZ/PHD
MOD