

PROFORMA REGARDING SANITARY CONDITION CERTIFICATE

Latter No II/644/050 CF/28-26

Date: 15/10/25

It is Certified that an inspection team headed by Rajnath Yadav, Sanitary and Food Inspector Health Dept. from Nagar Nigam Varanasi, Inspected the Premises of SUNBEAM SCHOOL, Annapurna, Lahartara, VARANASI on 09-10-2025 and found that the Premises of SUNBEAM SCHOOL has safe drinking water facilities for the students and member of staff of the institution and is maintain the hygienic Sanitation Condition in the School Building & the Campus as per the Norms Prescribed by the Central/State/U.T. Govt,

The above valid for a period of 1 Years.

SKR
Municipal Health Officer
Nagar Nigam, Varanasi

SKR
नगर स्वास्थ्य अधिकारी
नगर निगम वाराणसी

To,

SUNBEAM SCHOOL,
Annapurna, Laharta, Varanasi

Princip
Principal
SUNBEAM SCHOOL
Annapurna, Lahartara
Varanasi



Water Analysis Report



Regional Water Analysis Laboratory

(An NABL Accredited Laboratory)
Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005



TC-12093

Report No.: C/VNS/2025/000136	Date: 02.06.2025	No. of Pages: 1	
Customer Details			
Office Name and Address	SUNBEAM SCHOOL, ANNAPURNA LAHARTARA, VARANASI-221102		
Ref. Letter No. & Date	SBS/LHT/GEN/25/05/13(1)	Date: 13.05.2025	
Basic Details of Sample			
District	Varanasi	Block	NA
Gram Panchayat	NA	Village	NA
Habitatation	NA	Location	Lahartara, Varanasi
Water Source	RO Water	Sample Code	VNS/MAY25/00136
Quantity of Sample	1000 ml (Normal)	Sampling date	23.05.2025
Sample Received Date	23.05.2025	S. collected by	Mr Prem Prakash Yadav
Sampling Method Used	NA	Sample Depositor	Mr Rakesh Kumar Gupta
Analysis Start Date	25.05.2025	Analysis Completion date	25.05.2025

Temperature-25.4°C, Humidity-57%

Test Result

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.51	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Potentiometric Method
2	Turbidity (NTU)	2.84	1	5	IS 3025 (Part 10): 2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	125.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	12.68	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	74.67	200	600	IS 3025 (Part 23): 2023 (Potentiometric and Indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	21.33	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	6.15	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	1.44	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	5.81	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	4.43	45	No relaxation	APHA 24rd Edition -4500-NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.17	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method): 2023
12	Iron (as Fe), mg/l	BDL (<0.1)	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed


- Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
 3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurement.
 4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of an analysis report, unless otherwise specified.
 5. Parameters above Permissible Limit are written in bold.
 6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
 7. Sample is not Collected by Lab.

Aravind
Principal

SUNBEAM SCHOOL
Annapurna, Lahartara
Varanasi
(Report prepared by)

Aravind
02/06/2025

Vivekkumar
VIVEK KUMAR
(Report Reviewed by)



Laboratory Contact details: Email: aroupn@gmail.com Mobile No.: 8400202287

*****END OF THE ANALYSIS REPORT*****