PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Report No.: VNS/SAN2026/003

Date: 23.04.2026

It is certified that an inspection team headed by **Er. Shatrughan Kumar, Assistant Engineer** (Name of Officers with designation) from **U.P. Jal Nigam (Rural), Varanasi,** PHED inspected the **Sunbeam School Annapurna Lahartara Varanasi UP, Sunbeam School Annapurna Lahartara, Varanasi, Uttar Pradesh- 221002** (Name & Address of the school) on **23.04.2026** (date of inspection) and on the basis of Water Test Report (Attached) bearing no. **C/VNS/02/2026/0000044** dated **28.02.2026** of Regional **Water Analysis Laboratory, U. P. Jal Nigam (Rural), Ganga Pollution Control Unit Campus, Bhagwanpur, Lanka, Varanasi-221005** certified that the **Sunbeam School, Annapurna, Lahartara, Varanasi UP** (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of **1 Year** only.

Signature with seal

23/04/26

Name : Er. Shatrughan Kumar
Designation : Assistant Engineer
Name & Address of the Office/Department :U.P. Jal Nigam (Rural), Varanasi

Assistant Engineer
Vith C.D., U.P.J.N. (Gramin)
Varanasi

To,
Principal
Ms Perveen Queser
Sunbeam School Annapurna Lahartara Varanasi UP
Sunbeam School Annapurna Lahartara,
Varanasi, Uttar Pradesh- 221002.
(Name & Address of School)

Sunbeam School Annapurna, Lahartara, Varanasi
Aff.No.2130454

Sunbeam School Annapurna, Lahartara, Varanasi
School Code 71309

Note: The certificate is to be issued by authorized officer / PHED Lab. (Name of Officers with designation)

Water Analysis Report

Regional Water Analysis Laboratory

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005

Report No.: C/VNS/02/2026/0000044	Date: 28.02.2026	No. of Pages: 1

Customer Details

Office Name and Address	SUNBEAM SCHOOL, ANNAPURNA LAHARTARA, VARANASI-221002
Ref. Letter No. & Date	SBS/LHT/GEN/26/02/14(1) Date: 14.02.2026

Basic Details of Sample

District	Varanasi	Block	NA
Gram Panchayat	NA	Village	NA
Habitation	NA	Location	School Campus, Lahartara, Varanasi
Water Source	NA	Sample Code	VNS/FEB26/00044
Quantity of Sample	1000 mL (Normal)	Sampling date	25.02.2026
Sample Received Date	25.02.2026	S. collected by	Mr Satyedev Upadhyay
Sampling Method Used	NA	Sample Depositor	Mr Satyedev Upadhyay
Analysis Start Date	26.02.2026	Analysis Completion date	26.02.2026

Test Result Temperature- 24.4°C, Humidity- 56%

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.55	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.54	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	162.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	17.02	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO3) mg/l	70.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO3) mg/l	48.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	14.44	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	2.88	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO4), mg/l	9.68	200	400	APHA 24rd Edition -4500-SO4 Method E (Turbidimetric Method): 2023
10	Nitrate (as NO3), mg/l	9.21	45	No relaxation	APHA 24rd Edition -4500- NO3 Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.10	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method) : 2023
12	Iron (as Fe), mg/l	BDL (<0.1)	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permisible Limit are written in bold.
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab.
8. Source is not verified by the Lab

Sunbeam School Annapurna, Lahartara, Varanasi * School Code 71309 * Manager Correspondent *

ABHAY KUMAR DUBEY
(Report prepared by)

Sunbeam School Annapurna, Lahartara, Varanasi

VIVEK KUMAR
(Report Reviewed & Authorized by)

Regional Water Analysis Laboratory Quality Manager

Laboratory Contact detail: Email: upjn@gmail.com Mobile No.:8400202287

****END OF THE ANALYSIS REPORT****