



SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida-201301

Mob.: 9821154906, 8076937396, 9599753719

E-mail.: shriomlab@gmail.com, Web.: www.shriomlab.com, www.shriomlab.in

GSTIN: 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory

TEST- REPORT

Issued To: M/s. ST. JOHN'S SCHOOL
HS-01 Sector-2, Greater Noida
(WEST) U.P-203207

Report No.: STRL17042026003
Date of Completion: 17.04.2026

Sample Description: RO WATER (DRINKING WATER)

RESULTS (WATER QUALITY ANALYSIS) As per IS: 10500-2012


SAMPLING DETAILS

Reference Protocol : As per IS: 10500-2012
Sampling Protocol : IS -3025 (P-1)1987
Sample Received On : 13.04.2026
Sample Collected From : M/s. ST. JOHN'S SCHOOL
HS-01 Sector-2, Greater Noida
(WEST) U.P-203207
Sample Collected By : STRL Staff (VIJAY SHARMA)
Sampling Quantity : 2 Liter +500ml Sterilized Bottle
Sample Packing : Pet Bottle
Analysis Duration : 13.04.2026 to 17.04.2026

Sr. No.	Parameters	Units	Limits (as per IS:10500-2012)		Results	Conformity	Test Method
			Desirable Limit	Permissible Limit			
PHYSICO-CHEMICAL TEST RESULTS:							
01	Color	Hazen	5	15	<5	Yes	IS: 3025(Pt-4) 1983, Reaff2017
02	Taste	-	Agreeable	Agreeable	Agreeable	Yes	IS: 3025(Pt-8)-1984, Reaff2017
03	Turbidity	NTU	1	5	<1.0	Yes	IS: 3025(Pt-10)-1984, Reaff2017
04	pH	-	6.5-8.5	No Relaxation	7.28	Yes	IS: 3025(Pt-11)1983, Reaff2017
05	Electric Conductivity	µS/cm	-	-	221.6	yes	IS: 3025(Pt-14)2013
CHEMICAL TEST RESULTS:							
06	Total Hardness (as CaCO ₃)	mg/l	200	600	73.6	Yes	IS: 3025(Pt-21)1983, Reaff2014
07	Iron (as Fe)	mg/l	0.3	No Relaxation	0.1	Yes	APHA 23nd Ed. 2017, 3120B /3111B (AAS),

Page (01 of 02)

For Shri Om Testing & Research Laboratory


ISHWARI BHARDWAJ
Technical Manager

Authorised Signat
(Name, Designation & Signature with S

STRL/LAB/QF/058

Rev.:00

Note: 1. The results indicated only refer to the tested samples and listed parameters and do not endorse any product. The customer asked for the above tests only.

2. This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.

3. This certificate shall not be used in any advertising media or as evidence in the court of Law without prior written consent of the laboratory.

4. The samples received shall be destroyed after 30 days from the date of issue of the certificate unless specified otherwise and sample for biological testing will be destroyed after 7 days of test.



SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida-201301

Mob.: 9821154906, 8076937396, 9599753719

E-mail.: shriomlab@gmail.com, Web.: www.shriomlab.com, www.shriomlab.in

GSTIN: 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory.

TEST- REPORT

Report No.: STRL17042026003

08	Chlorides (as Cl)	mg/l	250	1000	39.8	Yes	IS: 3025(Pt-32)1988, Reaff2014
09	Fluoride (as F)	mg/l	1	1.5	0.1	Yes	APHA 23nd Ed. 2017, 4500F(D)
10	TDS	mg/l	500	2000	133	Yes	IS: 3025(Pt-16)1984, Reaff2017
11	Calcium (as Ca ²⁺)	mg/l	75	200	24.8	Yes	IS: 3025(Pt-40)1991, Reaff2014.
12	Magnesium (as Mg ²⁺)	mg/l	30	100	2.8	Yes	APHA 23nd Ed. 2017, 3500-Mg (B)
13	Copper (as Cu)	mg/l	0.05	1.5	0.01	Yes	APHA 23nd Ed. 2017, 3120 B / 3111B (AAS)
14	Manganese (as Mn)	mg/l	0.1	0.3	0.01	Yes	APHA 23nd Ed. 2017, 3120 B)/ 3111B(AAS)
15	Sulphate (as SO ₄)	mg/l	200	400	16.8	Yes	IS: 3025(Pt-24)1986, Reaff2014
16	Nitrate (as NO ₃)	mg/l	45	No Relaxation	12.2	Yes	IS: 3025(Pt-34)1988, Reaff2014
17	Phenolic Compounds (as C ₆ H ₅ OH)	mg/l	0.001	0.002	0.001	Yes	APHA 23nd Ed. 2017, 5530 C
18	Lead (as Pb)	mg/l	0.01	No Relaxation	0.01	Yes	APHA 23nd Ed. 2017, 3120 B /3111B AAS
19	Zinc (as Zn)	mg/l	5	15	0.2	Yes	APHA 23nd Ed. 2017, 3120 B / 3111 B (AAS)
20	Anionic Detergent (as MBAS)	mg/l	0.2	1	0.01	Yes	APHA 23nd Ed. 2017, 5540 (c)
21	Chromium (as Cr ⁶⁺)	mg/l	0.05	No Relaxation	0.05	Yes	IS: 3025(Pt-52)-2003 RA 2014
22	Mineral oil	mg/l	0.5	No Relaxation	0.1	Yes	IS: 3025(Pt-39)1991, Reaff2014
23	Alkalinity (as CaCO ₃)	mg/l	200	600	43.2	Yes	IS: 3025(Pt-23)1986, Reaff2014

BACTERIOLOGICAL PARAMETERS :-


01	Total Coli form	MPN/100ml	Should be absent	Absent	Yes	IS: 1622-1981 (Reaff.2003)
02	E. Coli	E. Coli/100ml	Should be absent	Absent	Yes	IS: 1622-1981 (Reaff.2003)

Remarks: The Sample Confirm IS-10500-2012 (DRINKING WATER) Specification, w.r.t for above Parameters

End of Report

Page (02 of 02)

For Shri Om Testing & Research Laboratory


ISHWAR BHARDWAJ
Technical Manager

Authorised Signatory
(Name, Designation & Signature with Seal)

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 2089

Dated: 15-05-2025

It is certified that an inspection team headed by Dr. Chandan Soni (Name of Officers with designation) from Deputy Cmo PHED inspected the ST.JOHN'S SCHOOL, HS-01,SECTOR-2,GREATER NOIDA WEST (Name & Address of the school) on 14.05.2025.(date of inspection) and on the basis of Water Test Report (Attached) bearing no STRLO7052025005 dated 07.05.2025 of (PHED Lab) certified that the ST.JOHN'S SCHOOL(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one Year.


उप मुख्य चिकित्सा अधिकारी
गौतम बुद्ध नगर

Signature with Seal: 
Name : Dr Narendra Kumar
Designation : Chief Medical Officer,
Name & Address of the Office / Department : Health

To
ST.JOHN'S SCHOOL
HS-01,SECTOR-2,
GREATER NOIDA WEST
(Name & Address of the Institution)

Note: The certificate is to be issued
authorized officer / PHED Lab / local
bodies