CERTIFICATE OF SAFERINKING WATER AND SANITARY CONDITION

No. 2809 Date: 17/06/2026

It is certified that an inspection team headed by Deputy CMO Gautam Budh Nagar from Dr. Chandan Soni PHED inspected **St. John's School** located at HS-01, Sector-2, Gr. Noida West, Gautam Budh Nagar on dated 16-06-2026 (Date of Inspection) and on the basis of Water Test Report (Attached) bearing no-STRL17042026003 on Dated-17-04-2026 of (PHED Lab) certified thate **St. John's School** located at HS-01, Sector-2, Gr. Noida West, Gautam Budh Nagar has safe drinking water facilities for the students and members of staff of the institution and is maintain the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

The above valid for a period of 1 Year.

Signature with Seal:- Chief Medical Officer Gautam Buddha Nagar

Name:- Dr. Madan Mohan Mani Tripathi

Designation:- Chief Medical Officer

उप मुख्य चिकित्सा अधिकारी
गौतमबुद्धनगर

To

The Principal,
St. John's School
HS-01, Sector-2, Gr. Noida West,
Gautam Budh Nagar.

SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida-201301
Mob.: 9821154906, 8076937396, 9599753719
E-mail.: shriomlab@gmail.com, **Web.:** www.shriomlab.com, www.shriomlab.in
GSTIN: 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory.

TEST- REPORT

Issued To: M/s. ST. JOHN'S SCHOOL
Address: HS-01 Sector-2, Greater Noida
(WEST) U.P-203207

Report No.: STRL16102026001
Date of Completion:16.10.2026

(LAB CERTIFICATE NUMBER:TC-14903

Sample Description: RO WATER (DRINKING WATER)

RESULTS
(WATER QUALITY ANALYSIS)
As per IS: 10500-2012

SAMPLING DETAILS

Reference Protocol	:	As per IS: 10500-2012
Sampling Protocol	:	IS -3025 (P-1)1987
Sample Received On	:	12.10.2026
Sample Collected From	:	M/s. ST. JOHN'S SCHOOL HS-01 Sector-2, Greater Noida (WEST) U.P-203207
Sample Collected By	:	STRL STAFF (VIJAY SHARMA)
Sampling Quantity	:	2 Liter +500ml Sterilized Bottle
Sample Packing	:	Pet Bottle
Analysis Duration	:	12.10.2026 to 16.10.2026

Sr. No.	Parameters	Units	Limits (as per IS:10500-2012) Desirable Limit	Permissible Limit	Results	Conformity	Test Method
PHYSICO -CHEMICAL TEST RESULTS:							
01	Taste	-	Agreeable	Agreeable	Agreeable	Yes	IS: 3025(Pt-8)-1984, Reaff2017
02	Temperature	°C	-	-	24.0	Yes	IS: 3025(Pt-8)-1984, Reaff2017
03	Electric Conductivity	µS/cm	-	-	112.8	Yes	IS: 3025(Pt-14)2013
04	pH	-	6.5-8.5	No Relaxation	7.04	Yes	IS: 3025(Pt-11)1983, Reaff2017
05	TDS	Mg/l	500	2000	67.7	Yes	IS: 3025(Pt-16)1984, Reaff2017
CHEMICAL TEST RESULTS:							
06	Total Hardness (as $CaCO_3$)	mg/l	200	600	44.2	Yes	IS: 3025(Pt-21)1983, Reaff2014
07	Iron (as Fe)	mg/l	0.3	No Relaxation	0.1	Yes	APHA 23nd Ed. 2017, 3120B /3111B (AAS),

For Shri Om Testing & Research Laboratory

16/10/26

ISHWAR BHARDWAJ
Technical Manager

Authorised Signatory
(Name, Designation & Signature with Seal)

SHRI OM TESTING & RESEARCH LABORATORY

Plot No. 296, 1st FNG Road, Sector-121, Ghari Chaukhandi, Noida-201301
Mob.: 9821154906, 8076937396, 9599753719
E-mail.: shriomlab@gmail.com, **Web.:** www.shriomlab.com, www.shriomlab.in
GSTIN: 09ADHFS2444J1ZS

N.A.B.L. Accredited, ISO 9001, ISO 14001 & ISO 45001 Certified Laboratory.

TEST- REPORT

Report No.: STRL16102026001

08	Chlorides (as Cl)	mg/l	250	1000	16.8	Yes	IS: 3025(Pt-32)1988, Reaff2014
09	Fluoride (as F)	mg/l	1	1.5	0.1	Yes	APHA 23nd Ed. 2017, 4500F(D)
10	Calcium (as Ca^{2+})	mg/l	75	200	9.6	Yes	IS: 3025(Pt-40)1991, Reaff2014.
11	Magnesium (as Mg^{2+})	mg/l	30	100	2.8	Yes	APHA 23nd Ed. 2017, 3500-Mg (B)
12	Copper (as Cu)	mg/l	0.05	1.5	0.01	Yes	APHA 23nd Ed. 2017, 3120 B / 3111B (AAS)
13	Manganese (as Mn)	mg/l	0.1	0.3	0.01	Yes	APHA 23nd Ed. 2017, 3120 B)/ 3111B(AAS)
14	Sulphate (as SO_4)	mg/l	200	400	12.4	Yes	IS: 3025(Pt-24)1986, Reaff2014
15	Nitrate (as NO_3)	mg/l	45	No Relaxation	11.2	Yes	IS: 3025(Pt-34)1988, Reaff2014
16	Phenolic Compounds (as C_6H_5OH)	mg/l	0.001	0.002	0.001	Yes	APHA 23nd Ed. 2017, 5530 C
17	Lead (as Pb)	mg/l	0.01	No Relaxation	0.01	Yes	APHA 23nd Ed. 2017, 3120 B /3111B AAS
18	Zinc (as Zn)	mg/l	5	15	0.2	Yes	APHA 23nd Ed. 2017, 3120 B / 3111 B (AAS)
19	Anionic Detergent (as MBAS)	mg/l	0.2	1	0.01	Yes	APHA 23nd Ed. 2017, 5540 (c)
20	Chromium (as Cr^{6+})	mg/l	0.05	No Relaxation	0.05	Yes	IS: 3025(Pt-52)-2003 RA 2014
21	Mineral oil	mg/l	0.5	No Relaxation	0.1	Yes	IS: 3025(Pt-39)1991, Reaff2014
22	Alkalinity (as $CaCO_3$)	mg/l	200	600	23.2	Yes	IS: 3025(Pt-23)1986, Reaff2014
BACTERIOLOGICAL PARAMETERS :							
01	Total Coli form	MPN/100ml	Should be absent		Absent	Yes	IS: 1622-1981 (Reaff.2003)
02	E. Coli	E. Coli/100ml	Should be absent		Absent	Yes	IS: 1622-1981 (Reaff.2003)

Remarks: The Sample Confirm IS-10500-2012 (DRINKING WATER) Specification, w.r.t for above Parameters

End of Report

For Shri Om Testing & Research Laboratory

16/10/25

MEHWAR BHARDWAJ
Technical Manager
Authorised Signatory
(Name, Designation & Signature with Seal)