



TC-14227

**POLLUCON** LABORATORIES PVT. LTD.**Test Report**QF/7.8/01
ULR No : TC14227250000013693F
Page 1 of 1

Customer's Name and Address :

**TAPTI VALLEY INTERNATIONAL SCHOOL
BLOCK NO.456-57, NARTHAN JAHANGIRPURA DANDI ROAD,
TA. OLPAD, SURAT.-395005**Test Report No : PLPL/W/25/11/24/0030
Issue Date : 29/11/2025
Customer's Ref. : Verbal

Description of Sample : **Water** Qty / Nos of Sample : **01 Ltr / 01**
 Date of Sampling : **24/11/2025** Protocol / Purpose : **Quality Check**
 Sample Receipt Date : **24/11/2025** Sampling Procedure : **Not Applicable**
 Packing / Seal : **Sealed** Lab ID : **PLPL/W/25/11/24/0030**
 Date of Starting of Test : **24/11/2025** Date of Completion : **29/11/2025**
 Sampling By : **Pollucon Team (Mukesh Kachhadiya)**
 Identification of Sample # : **RO Water**

RESULT TABLE

S.NO	TEST PARAMETER	UNIT	RESULT	DESIRABLE LIMIT AS PER IS 10500 : 2012	TEST METHOD
1	Odour	--	Agreeable	Agreeable	IS 3025 (Part 5)
2	Colour	Hazen	4	Max 5	IS 3025 (Part 4) Clause.5
3	Taste	--	Agreeable	Agreeable	IS 3025 (Part 8)
4	pH	--	7.51	6.5 to 8.5	IS 3025 (Part 11) Clause.2
5	Turbidity	NTU	0.06	Max 1	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/L	12	Max 500	IS 3025 (Part 16)
7	Total Hardness as CaCO ₃	mg/L	4	Max 200	IS 3025 (Part 21) Clause.5
8	Chloride	mg/L	3.49	Max 250	IS 3025 (Part 32) Clause.2
9	Fluoride	mg/L	LTAR(<0.05)	Max 1	APHA (24th Edition) 4500 F D
10	Iron as Fe	mg/L	LTAR(<0.05)	Max 1	APHA(24th Edition) 3500 Fe B
11	Coliforms	/100 ml	Absent	Absent	IS 15185
12	Escherichia coli	/100 ml	Absent	Absent	IS 15185

Note : LTAR :- Lower Than Accreditation Range

Note : Sample found conforming as per IS 10500:2012 standard for the tested parameters.

TAPTI VALLEY INTERNATIONAL SCHOOL

**Ms. Urvi Parekh
Sr Chemist****Dr. Harshal Gandhi
Sr. Microbiologist****Dr. Arun Bajpai
Authorized Signatory**

Note : This Report is subject to terms & conditions mentioned overleaf. (# : Details given by Customer)

● Recognised Env. Lab under
Env. (Protection) Act-1986 (CPCB)● Recognised Schedule II
Env. Auditor (GPCB)

*** End of Report ***

● ZDHC Approved for
Wastewater Guidelines V2.2

● ISO 9001 / 14001 / 45001



POLLUCON LABORATORIES PVT. LTD.

QF/7.8/01

ULR No : TC14227250000013694F

Page 1 of 1

Test Report

TC-14227
Customer's Name and Address :

TAPTI VALLEY INTERNATIONAL SCHOOL
BLOCK NO.456-57, NARTHAN JAHANGIRPURA DANDI ROAD,
TA. OLPAD, SURAT.-395005

Test Report No : **PLPL/W/25/11/24/0031**
Issue Date : **29/11/2025**
Customer's Ref. : **Verbal**

Description of Sample : **Water** Qty / Nos of Sample : **01 Ltr / 01**
Date of Sampling : **24/11/2025** Protocol / Purpose : **Quality Check**
Sample Receipt Date : **24/11/2025** Sampling Procedure : **Not Applicable**
Packing / Seal : **Sealed** Lab ID : **PLPL/W/25/11/24/0031**
Date of Starting of Test : **24/11/2025** Date of Completion : **29/11/2025**
Sampling By : **Pollucon Team (Mukesh Kachhadiya)**
Identification of Sample # : **Sports Complex Water**

RESULT TABLE

S.NO	TEST PARAMETER	UNIT	RESULT	DESIRABLE LIMIT AS PER IS 10500 : 2012	TEST METHOD
1	Odour	--	Agreeable	Agreeable	IS 3025 (Part 5)
2	Colour	Hazen	4	Max 5	IS 3025 (Part 4) Clause.5
3	Taste	--	Agreeable	Agreeable	IS 3025 (Part 8)
4	pH	--	6.86	6.5 to 8.5	IS 3025 (Part 11) Clause.2
5	Turbidity	NTU	0.08	Max 1	IS 3025 (Part 10)
6	Total Dissolved Solids	mg/L	169	Max 500	IS 3025 (Part 16)
7	Total Hardness as CaCO ₃	mg/L	34	Max 200	IS 3025 (Part 21) Clause.5
8	Chloride	mg/L	58.98	Max 250	IS 3025 (Part 32) Clause.2
9	Fluoride	mg/L	LTAR(<0.05)	Max 1	APHA (24th Edition) 4500 F D
10	Iron as Fe	mg/L	LTAR(<0.05)	Max 1	APHA(24th Edition) 3500 Fe B
11	Coliforms	/100 ml	Absent	Absent	IS 15185
12	Escherichia coli	/100 ml	Absent	Absent	IS 15185

Note : LTAR :- Lower Than Accreditation Range

Note : Sample found conforming as per IS 10500:2012 standard for the tested parameters.

TAPTI VALLEY INTERNATIONAL SCHOOL

V. Srinivasan
PRINCIPAL

Ms. Urvi Parekh
Sr Chemist

Dr. Harshal Gandhi
Sr. Microbiologist

Dr. Arun Bajpai
Authorized Signatory

Note : This Report is subject to terms & conditions mentioned overleaf. (# : Details given by Customer)

● Recognised Env. Lab under
Env. (Protection) Act-1986 (CPCB)

● Recognised Schedule II
Env. Auditor (GPCB)

*** End of Report ***
● ZDHC Approved for
Wastewater Guidelines V2.2

● ISO 9001 / 14001 / 45001



PRIMARY HEALTH CENTER



DIHEN

TA- OLPAD, DIST- SURAT

HEALTH & SANITARY CONDITION CERTIFICATE

DATE :- 01/02/2022

It is certified that an duly constituted inspection team inspected the Tapti Valley International School , Block No 456-457, Village Narthan, Rander – Dandi Road, Taluka Olpad, Surat, Gujarat – 395005 and found that the Tapti Valley International School is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by Government of Gujarat.

The above Certificate is Valid for a period of Three Years.

TAPTI VALLEY INTERNATIONAL SCHOOL

[Signature]
PRINCIPAL

[Signature]
Medical Officer

Medical Officer
Phc Dihen
Primary Health Centre
Dihen, Tal. Olpad.
Reg. No. G-31071



નરથાણ ગ્રામ પંચાયત

તા. ઓલપાડ, જી. સુરત.

સરપંચશ્રી : નિશાબેન ઉમેશભાઈ પટેલ

જા.નં : ૨૦૨૧-૨૨

તારીખ : ૩૧/૦૧/૨૦૨૧

TO WHOM SO EVER IT MAY CONCERN

THIS IS TO CERTIFY THAT TAPTI VALLEY INTERNATIONAL SCHOOL BLOCK NO.456-457, NARTHAN DANDI ROAD, SURAT COMES UNDER GRAM PANCHAYAT – NARTHAN IS FOLLWING ALL THE HEALTH & SANIYARY NORMS AS PRESCRIBED.

Sushanti Jyoti M.
સરપંચ
નરથાણ ગ્રામ પંચાયત
તા. ઓલપાડ, જિ. સુરત.

SARPANCH

GRAM PANCHAYAT, NARTHAN

TAPTI VALLEY INTERNATIONAL SCHOOL


PRINCIPAL